



*alpha*

Alpha Analytical Laboratories, Inc.

email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

24 May 2021

Volcano CSD

Attn: Nick Lawson

P O Box 72

Volcano, CA 95689

RE: Source Chemical Monitoring

Work Order: 21E1834

Enclosed are the results of analyses for samples received by the laboratory on 05/13/21 22:20. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

*Sheri Speaks*

Sheri L. Speaks For Karen L. Lantz

Project Manager



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728  
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922  
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303  
San Diego: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510 | ELAP# 3055

Volcano CSD	Project:	Source Chemical Monitoring	
P O Box 72	Project #:	0300016	Reported:
Volcano CA, 95689	Project Mgr:	Nick Lawson	05/24/21 07:50

### Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Finished Water	21E1834-01	Water	05/13/21 08:00	05/13/21 22:20



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Sample Name: Finished Water  
Laboratory ID: 21E1834-01

Report Date: 05/24/21 07:50  
Laboratory Code: 1610

System Name: VOLCANO COMMUNITY SERVICE DIST  
Source Name: 0300016-005 WELL 01 AND 02 PLANT  
Sampled by: Joel  
Employed by: Volcano CSD

Sample Date: 05/13/21 08:00  
Sample Received: 05/13/21 22:20  
User ID: 03C  
System Number: 0300016

Data submitted to DDW via EDT

### General Mineral and Physical

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Color	<5.0	15		CU	00081	SM2120B	2922
Turbidity	<0.10	5		NTU	82079	SM2130B	2922

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Iron	<100	300	100	ug/L	01045	EPA 200.7	1551
Manganese	<20	50	20	ug/L	01055	EPA 200.7	1551



*alpha*

---

Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

**Notes and Definitions**

- \* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.



Corporate Laboratory  
208 Mason Street, Ukiah CA 95482  
707-468-0401 F) 707-468-5267  
email: clientservices@alpha-labs.com

www.alpha-labs.com

WATERS, SEDIMENTS, SOLIDS

ELAP Certifications  
Ukiah 1551 / Dublin 2728 / Elk Grove 2922

Bay Area Laboratory  
262 Rickenbacker Circle, Livermore, CA 94551  
925-828-6226 F) 925-828-6309

Central Valley Laboratory  
9090 Union Park Way #113, Elk Grove CA 95624  
916-686-5190 F) 916-686-5192

# Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 21E1834 Pg      of     

Signature below authorizes work under terms stated on reverse side.

Report to		Invoice to (if different)		Project Information				Analysis Request		TAT		Temp upon Receipt °C	
Company: Volcano CSD		Contact: Email address: Address: Phone/Fax:		Project ID: SCM - MONTHLY		Project No: 0300016		Standard 10 days		Standard 5 days X 48 hours		Ukiah temp: 1.2	
Address: PO Box 72 Volcano, CA 95689 Phone/Fax: 209-304-7628 Email Address: niwsp49@gmail.com		Internal Lab Use: 355		PO Number: 0300016		CV - Color - 500 mL Amber		Other: days		Lab preapproval required		Dublin temp:	
Field Sampler - Printed Name & Signature: <u>JDEUT. MOTTISHAW</u> 		40ml Vial		NaOH		CV - Turbidity - 500 mL		Other: days		Elk Grove temp: 4.8		Sample Notes or CDPH Source Numbers: C300016-005TRT	
Sample Identification		Sampling		Container		Preservative		Matrix		Total Number of Containers per Sample ID		CDPH Write On EDT Transmission?	
Date		Time		40ml Vial	Poly	HCl	None	Soil	1		Yes		No
5-13-21		0800		Glass	X	Other	X	Water DW	1		No		No
Well 01 & 02 Plant				Sleeve		Na2S2O3	X	Other	1		Yes		No
											State System Number: 0300016		
											If "Y" please enter the Source Number(s) in the column above		
											Mail Hardcopy to DDW-?		
JDEUT. MOTTISHAW C DB2D		5-13-21 1240									Hardcopy to DDW attn:		
		5-13-21 1400									Misc Supplies:		
		5-13-21 1500									Travel and Site Time		
		5-13-21 1900											
		5-15-21 2220											