



alpha

Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

13 March 2021

Volcano CSD

Attn: Nick Lawson

P O Box 72

Volcano, CA 95689

RE: Source Chemical Monitoring

Work Order: 21B3721

Enclosed are the results of analyses for samples received by the laboratory on 02/25/21 23:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Chelsea Sandelin

Chelsea L. Sandelin For Karen L. Lantz

Project Manager



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303
San Diego: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510 | ELAP# 3055

Volcano CSD	Project:	Source Chemical Monitoring	
P O Box 72	Project #:	0300016 / Monthly	Reported:
Volcano CA, 95689	Project Mgr:	Nick Lawson	03/11/21 16:53

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Finished Well Water	21B3721-01	Water	02/25/21 09:30	02/25/21 23:45



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Sample Name: Finished Well Water
Laboratory ID: 21B3721-01

Report Date: 03/11/21 16:53
Laboratory Code: 1610

System Name: VOLCANO COMMUNITY SERVICE DIST
Source Name: 0300016-005 WELL 01 AND 02 PLANT
Sampled by: Nick Lawson
Employed by: Volcano CSD

Sample Date: 02/25/21 09:30
Sample Received: 02/25/21 23:45
User ID: 03C
System Number: 0300016

Data submitted to DDW via EDT

General Mineral and Physical

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Color	<5.0	15		CU	00081	SM2120B	2922
Turbidity	<0.10	5		NTU	82079	SM2130B	2922

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Iron	<100	300	100	ug/L	01045	EPA 200.7	1551
Manganese	<20	50	20	ug/L	01055	EPA 200.7	1551



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Notes and Definitions

- * Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

Chain of Custody - Work Order

Reports and invoices delivered by email in PDF format

Bay Area Laboratory
 262 Rickenbacker Circle, Livermore, CA 94551
 925-828-6226 F) 925-828-6309

Corporate Laboratory
 208 Mason Street, Ukiah CA 95482
 707-468-0401 F) 707-468-5267
 email: clientservices@alpha-labs.com


Alpha Analytical Laboratories, Inc.
 www.alpha-labs.com
WATERS, SEDIMENTS, SOLIDS

Central Valley Laboratory
 9090 Union Park Way #113, Elk Grove CA 95624
 916-886-5190 F) 916-886-5192

ELAP Certifications
 Ukiah 1551 / Dublin 2728 / Elk Grove 2922

Lab No 2133721 Pg of

Signature below authorizes work under terms stated on reverse side.

Report to		Invoice to (if different)		Project Information		Analysis Request		TAT	Temp upon Receipt °C	
Company:	Volcano CSD	Contact:	Volcano CSD	Project ID:	SCM - MONTHLY	Standard 10 days Standard 5 days <input checked="" type="checkbox"/> 48 hours Other: _____ days		Standard 10 days	Ukiah temp: 2.4	
Attn:	Nick Lawson	Email address:	Nick Lawson	Project No:	0300016			Lab preapproval required	Dublin temp:	Dublin temp:
Address:	PO Box 72 Volcano, CA 95689	Address:	PO Box 72 Volcano, CA 95689	PO Number:	0300016			Other: _____ days	Elk Grove temp:	Elk Grove temp: 4.4
Phone/Fax:	209-304-7628	Phone/Fax:	209-304-7628	Internal Lab Use:	355	Total Number of Containers per Sample ID CV - Color 500ML CV - Turbidity 500ML Fe, Mn by 200.7		Sample Notes or CDPH Source Numbers: 0300016-005TRT		
Field Sampler - Printed Name & Signature: Nick Lawson <i>Nick Lawson</i>			Container		Preservative		Matrix			
Sample Identification			Poly	HCl	NaOH	Na2S2O3	None	Water DW		Sample Notes or CDPH Source Numbers: 0300016-005TRT
Finished Well Water			Glass	Other	None	None	None	Other		
Date			40ml Vial	Sleeve	None	None	None	Other		
Time			Other	Other	None	None	None	Other		
Date			Sample Information		Preservative		Matrix			Sample Notes or CDPH Source Numbers: 0300016-005TRT
Time			Poly	HCl	NaOH	Na2S2O3	None	Water DW		
Date			Glass	Other	None	None	None	Other		
Time			40ml Vial	Sleeve	None	None	None	Other		
Relinquished by		Received by			Date	Time	CDPH Write On EDT Transmission?			
Nick Lawson		K AM			2/25	1000	Yes	State System Number: 0300016 If "Y" please enter the Source Number(s) in the column above		
LOUNGEY		AM			2/25	1052	No	Mail Hardcopy to DDW-? Yes No Hardcopy to DDW attn:		
AM		AM			2/25/21	1424	Travel and Site Time: Mileage: Misc Supplies:			
AM		ED			2/25/21	2040	Travel and Site Time: Mileage: Misc Supplies:			
AM		ED			2/25/21	2345	Travel and Site Time: Mileage: Misc Supplies:			