



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

11 May 2021

Volcano CSD

Attn: Nick Lawson

P O Box 72

Volcano, CA 95689

RE: Source Chemical Monitoring

Work Order: 21D2700

Enclosed are the results of analyses for samples received by the laboratory on 04/21/21 22:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Faydra K. Phenix For Karen L. Lantz

Project Manager



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303
San Diego: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510 | ELAP# 3055

Volcano CSD	Project:	Source Chemical Monitoring	
P O Box 72	Project #:	0300016 / Quarterly	Reported:
Volcano CA, 95689	Project Mgr:	Nick Lawson	05/10/21 15:34

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Finished Well Water Well 01 & 02 Plant	21D2700-01	Water	04/21/21 07:20	04/21/21 22:45



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Sample Name: Finished Well Water Well 01 & 02 Plant
Laboratory ID: 21D2700-01

Report Date: 05/10/21 15:34
Laboratory Code: 1610

System Name: VOLCANO COMMUNITY SERVICE DIST
Source Name: 0300016-005 WELL 01 AND 02 PLANT
Sampled by: Nick Lawson
Employed by: Volcano CSD

Sample Date: 04/21/21 07:20
Sample Received: 04/21/21 22:45
User ID: 03C
System Number: 0300016

Data submitted to DDW via EDT

General Mineral and Physical

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Color	<5.0	15		CU	00081	SM2120B	2922
Turbidity	<0.10	5		NTU	82079	SM2130B	2922

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Iron	<100	300	100	ug/L	01045	EPA 200.7	1551
Manganese	<20	50	20	ug/L	01055	EPA 200.7	1551



alpha

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Notes and Definitions

- * Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Bay Area Laboratory
262 Rickenbacker Circle, Livermore, CA 94541
925-828-6226 F) 925-828-6309

Central Valley Laboratory
9090 Union Park Way #113, Elk Grove CA 95624
916-686-5190 F) 916-686-5192

Corporate Laboratory
208 Mason Street, Ukiah CA 95482
707-468-0401 F) 707-468-5267
email: clientservices@alpha-labs.com

ELAP Certifications
Ukiah 1551 / Dublin 2728 / Elk Grove 2922

Alpha
Analytical Laboratories, Inc.
www.alpha-labs.com
WATERS, SEDIMENTS, SOLIDS

Lab No 21D2700 Pg of

Signature below authorizes work under terms stated on reverse side.

Report to		Invoice to (if different)		Project Information		Analysis Request		TAT		Temp upon Receipt °C					
Company: Volcano CSD		Contact:		Project ID: SCM - QUARTERLY		Standard 10 days		Standard 5 days		Ukiah temp: 1.8					
Attn: Nick Lawson		Email address:		Project No: 0300016		Standard 48 hours		X		Dublin temp:					
Address: PO Box 72, Volcano, CA 95689		Address:		PO Number:		Other: ___ days		Lab preapproval required		Elk Grove temp: 4.5					
Phone/Fax: 209-304-7628		Phone/Fax:		Internal Lab Use: 355											
Email Address: nlsn49@gmail.com															
Field Sampler - Printed Name & Signature: Nick Lawson / [Signature]															
Sample Identification	Sampling		Container	Preservative	Matrix	Total Number of Containers per Sample ID	CV - Color	CV - Turbidity	Fe, Mn by 200.7	Analysis Request	Time	Date	CDPH Write On EDT Transmission?	Yes	No
	Date	Time													
Finished Well Water	4-21	0720	X	None	Water DW	1	X	X				4-21	0745		
Well 01 & 02 Plant	[Signature]	[Signature]	X	HNO3	None	1			X			4-21-21	0820		
Cleveland Tunnel	4-21	0720	X			1						4-21-21	1420		
												4-21-21	1611		
												4-21-21	1210		
												4-21-21	2245		

Sample Notes or CDPH Source Numbers: 0300016-005TRT

Relinquished by: [Signatures]

CDPH Write On EDT Transmission? State System Number: 0300016

If "Y" please enter the Source Number(s) in the column above

Mail Hardcopy to DDW-? Yes No

Hardcopy to DDW attn: [Signature]

Misc. Supplies: [Signature]

